

**APPLICATION AND
CERTIFICATION IN LIEU OF
INSPECTION FOR CERTIFICATE
OF SMOKE DETECTOR AND
CARBON MONOXIDE ALARM
AND PORTABLE FIRE
EXTINGUISHER COMPLIANCE**

Borough of Palisades Park
Bergen County, N.J. 07650

BUREAU OF FIRE PREVENTION
275 BROAD AVENUE
PALISADES PARK, NEW JERSEY 07650
PHONE: (201) 585-4132
FAX: (201) 944-8059



DWELLING LOCATION: _____ BLOCK: _____ LOT: _____
(NOT MAILING ADDRESS)
STREET: _____

*NOTE: ALL BOXES MUST BE CHECKD IN ORDER FOR CERTIFICATION TO BE VALID

SMOKE DETECTORS SHALL BE LOCATED:

- A. IF CONSTRUCTED PRIOR TO 1977 ON EACH LEVEL OF DWELLING AND WITHIN 10 FEET OF SLEEPING AREAS. (DETECTORS MAY BE BATTERY POWERED.) DETECTORS MUST BE MOUNTED ON THE CEILING OR ON THE WALL WITHIN 6" OF THE CEILING.
- B. IF CONSTRUCTED BETWEEN 1977 AND 1989 ON EACH LEVEL OF DWELLING AND WITHIN 10 FEET OF SLEEPING AREAS. (DETECTORS MUST BE 110V) DETECTORS MUST BE MOUNTED ON THE CEILING OR ON THE WALL WITHIN 6" OF THE CEILING.
- C. IF CONSTRUCTED AFTER 1990 ON EACH LEVEL OF DWELLING, INSIDE OF EACH SLEEPING ROOM AND WITHIN 10 FEET OF SLEEPING AREAS. (DETECTORS MUST BE 110V WITH BATTERY BACK-UP, AND BE INTERCONNECTED.) DETECTORS MUST BE MOUNTED ON THE CEILING OR ON THE WALL WITHIN 6" OF THE CEILING.
- D. BATTERIES IN ALL SMOKE DETECTORS SHALL BE TESTED ONCE A MONTH AND CHANGED ONCE A YEAR TO ASSURE PROPER OPERATION.
- E. ALL SMOKE DETECTORS WITH A MANUFACTURE DATE GREATER THAN 10 YEARS MUST BE REPLACED.

_____ DETECTOR DATE OF MANUFACTURE

CARBON MONOXIDE DETECTORS SHALL BE LOCATED:

- A. WITHIN 10 FEET OF ALL SLEEPING AREAS.
- B. ALL CARBON MONOXIDE DETECTORS WITH A MANUFACTURE DATE GREATER THAN 5 YEARS MUST BE REPLACED.

_____ DETECTOR DATE OF MANUFACTURE

ALL SMOKE DETECTORS ARE IN WORKING ORDER. CARBON MONOXIDE ALARM(S) IN WORKING ORDER

FIRE EXTINGUISHER IS THE CORRECT SIZE, IS PROPERLY MOUNTED, AND IS LOCATED WITHIN 10 FEET OF THE KITCHEN

MAIL CERTIFICATE TO: _____ PHONE #: _____

FAX #: _____

ZIP: _____

CONTACT PERSON: _____ PHONE #: _____ CLOSING DATE: _____

I _____ HEREBY CERTIFY THAT AT THE ABOVE REFERENCED LOCATION, OF WHICH I AM THE OWNER, AGENT, TENANT, OR NJ LICENSED ELECTRICIAN, THE FOLLOWING ITEMS HAVE BEEN INSTALLED, MAINTAINED, AND CHECKED FOR PROPER OPERATION IN ACCORDANCE WITH N.J.A.C. 5:70-2.3, N.J.A.C. 5:70-4.19, N.J.A.C. 5:70-3,907.21, N.J.A.C. 5:70-3,703.2.3, AND NFPA 72.

DATE

APPLICANT SIGNATURE

PRINTED NAME